

# Fire Alarm and Life Safety System Inspection Certificate

*For*

2014 Sample Inspection Report  
123 Main Street  
Anywhere, State 90009

Tested to NFPA 72 Standards

*This Inspection was performed in accordance with applicable NFPA Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*Inspection Date*  
*Jan 10, 2014*

Building: 2014 Sample Inspection Report  
Contact: John Williams  
Title: Property Manager

Company: BuildingReports Demonstration Company  
Contact: John Doe  
Title: Inspector

# Executive Summary

Generated by: BuildingReports.com

Building Information		
<b>Building:</b> 2014 Sample Inspection Report	<b>Contact:</b> John Williams	
<b>Address:</b> 123 Main Street	<b>Phone:</b> 555-555-5555	
<b>Address:</b>	<b>Fax:</b>	
<b>City/State/Zip:</b> Anywhere, State 90009	<b>Mobile:</b>	
<b>Country:</b> United States of America	<b>Email:</b>	
Inspection Performed By		
<b>Company:</b> BuildingReports Demonstration Company	<b>Inspector:</b> John Doe	
<b>Address:</b> 1325 Satellite Blvd	<b>Phone:</b> 770-555-5555	
<b>Address:</b> Suite 1607	<b>Fax:</b>	
<b>City/State/Zip:</b> Suwanee, Georgia 30024	<b>Mobile:</b>	
<b>Country:</b> United States of America	<b>Email:</b> jdoe@abcfire.com	
System Control Unit		
<b>Manufacturer:</b> EST	<b>Inspection Date:</b> 01/10/2014	<b>IDC Style:</b> B
<b>Model Number:</b> 3	<b>Install Date:</b> 05/01/2004	<b>SLC Style:</b> 2
<b>Software Version:</b> 3.0	<b>Version Date:</b> 05/07/2008	<b>NAC Style:</b> X
<b>Location:</b> 1st FACP Room	<b>Current Protection:</b> Breaker	
Monitoring		
<b>Type:</b> Digital Communicator	<b>Mfg:</b> EST	<b>Model #:</b> 3-MODCOM
<b>Test Time/Date:</b> 1/10/14 3:37:14 PM	<b>Restore Time:</b> 3:45pm	

Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Supervisory	5	4.72%	5	100.00%	5	100.00%	0	0%
Monitor	5	4.72%	1	20.00%	1	100.00%	0	0%
Auxiliary	14	13.21%	14	100.00%	14	100.00%	0	0%
Sound Test	11	10.38%	11	100.00%	11	100.00%	0	0%
Initiating	42	39.62%	40	95.24%	36	90.00%	4	10.00%
Alarm	1	0.94%	1	100.00%	0	0%	1	100.00%
Control	28	26.42%	28	100.00%	26	92.86%	2	7.14%
<b>Totals</b>	<b>106</b>	<b>100%</b>	<b>100</b>	<b>94.34%</b>	<b>93</b>	<b>93.00%</b>	<b>7</b>	<b>7.00%</b>



### Certification

Building: 2014 Sample Inspection Report

Company: BuildingReports Demonstration Company

Contact: John Williams

Inspector: John Doe

Signed: Jan 15, 2014 5:02:16 PM

Signed: Jan 15, 2014 5:02:27 PM

### John Doe

Certification Type	Number
IMSA Fire Alarm Interior Level I	123456
NICET Fire Alarm Systems Level II	456789

# Discrepancy Report

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: 2014 Sample Inspection Report		Control Panel: 1 - EST 3		
<p><i>The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is listed on the Consumer Product Safety Commission's website and is subject to a recall by the manufacturer is included.</i></p>				
Device Type	Manufacturer	ModelNumber	Date	Qty
<b>Items listed for Recall by Manufacturer</b>				
Power Supply	Fire-Lite	FCPS-24FS6	03/11/2003	1
<b>More Information:</b> <a href="http://www.cpsc.gov/cpscpub/prerel/prhtml03/03527.html">http://www.cpsc.gov/cpscpub/prerel/prhtml03/03527.html</a>				
Power Supply	Notifier	FCPS-24S8	03/11/2003	1
<b>More Information:</b> <a href="http://www.cpsc.gov/cpscpub/prerel/prhtml03/03527.html">http://www.cpsc.gov/cpscpub/prerel/prhtml03/03527.html</a>				
🔍 ScanID	📍 Location	🔑 Problem	📍 Address	📖 Reference
<b>Alarm</b>				
<b>Pre-Action System</b>				
02366557	3rd Computer Room	Access Denied	1-01013011	NFPA 72 10.2.3.1,2
<b>Control</b>				
<b>Battery</b>				
01001808	1st FACP Room-Power Supply	Date Expired	1	NFPA 72 T10.4.2.2.5(b)
01001809	1st FACP Room-Power Supply	Failed Test	1	NFPA 72 Table 10.4.2.2.5(a-e)
<b>Initiating</b>				
<b>Pull Station</b>				
01001817	3rd Stair A	Failed Operation	1-01011025	NFPA 72 10.2.1.2.2,3
<b>Smoke Detector</b>				
02366554	3rd Computer Room	Access Denied	1	NFPA 72 10.2.3.1,2
02366555	3rd Computer Room	Access Denied	1	NFPA 72 10.2.3.1,2
01001800	3rd Elevator Lobby	Failed to Report	1-01012325	NFPA 72 10.2.1.2.2,3
<b>Code References</b>				
NFPA 72 10.2.3.1,2	Before proceeding with any testing, all persons and facilities receiving alarm, supervisory, or trouble signals, and all building occupants shall be notified of the testing to prevent unnecessary response. At the conclusion of testing, those previously notified (and others, as necessary) shall be notified that testing has been concluded.			
NFPA 72 T10.4.2.2.5(b)	Batteries shall be replaced in accordance with the recommendations of the alarm equipment manufacturer or when the recharged battery voltage or current falls below the manufacturer's recommendations.			
NFPA 72 Table 10.4.2.2.5(a-e)	(a) Batteries shall be inspected for corrosion or leakage. Tightness of connections shall be checked and ensured. If necessary, battery terminals or connections shall be cleaned and coated. Electrolyte level in			

lead-acid batteries shall be visibly inspected.

(b) Batteries shall be replaced in accordance with the recommendations of the alarm equipment manufacturer or when the recharged battery voltage or current falls below the manufacturer's recommendations.

(c) Operation of battery charger shall be checked in accordance with charger test for the specific type of battery.

(d) Discharge Test: With the battery charger disconnected, the batteries shall be load tested following the manufacturer's recommendations. The voltage level shall not fall below the levels specified.

Exception: An artificial load equal to the full fire alarm load connected to the battery shall be permitted to be used in conducting this test.

(e) With the battery charger disconnected, the terminal voltage shall be measured while supplying the maximum load required by its application. The voltage level shall not fall below the levels specified for the specific type of battery. If the voltage falls below the level specified, corrective action shall be taken and the batteries shall be retested. Exception: An artificial load equal to the full fire alarm load connected to the battery shall be permitted to be used in conducting this test.

System defects and malfunctions shall be corrected. If a defect or malfunction is not corrected at the conclusion of system inspection, testing, or maintenance, the system owner or the owner's designated representative shall be informed of the impairment in writing within 24 hours.

NFPA 72  
10.2.1.2.2,3

# Proposed Solutions Report

Generated by: *BuildingReports.com*

Building: 2014 Sample Inspection Report		Control Panel: 1 - EST 3			
<p><i>The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.</i></p>					
🔍 ScanID	📍 Location	🔧 Solution	Model #	Cost	Fix
<b><i>Alarm</i></b>					
<b>Pre-Action System</b>					
02366557	3rd Computer Room	Reschedule	SHP -1	T/M	✱
<b><i>Control</i></b>					
<b>Battery</b>					
01001808	1st FACP Room-Power Supply	Replace	PS-127	\$76.00	✱
01001809	1st FACP Room-Power Supply	Replace	PS-127	\$76.00	✱
<b><i>Initiating</i></b>					
<b>Pull Station</b>					
01001817	3rd Stair A	Replace	SIGA-278	\$220.00	✱
<b>Smoke Detector</b>					
02366554	3rd Computer Room	Reschedule	SIGA-PS	T/M	✱
02366555	3rd Computer Room	Reschedule	SIGA-PS	T/M	✱
01001800	3rd Elevator Lobby	Correct	SIGA-PS	T/M	✱

# Notes & Recommendations

Generated by: *BuildingReports.com*

## Building: 2014 Sample Inspection Report

*The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.*

### **General Note**

Security could not provide inspection team with access to the 3rd floor computer room preaction system.  
Recommend rescheduling to provide access for inspection and testing.

## Building: 2014 Sample Inspection Report Control Panel: 1 - EST 3

ScanID	Not e	Device Type	Location	Comment
<b>Control</b>				
01821493	2	Communicator	1st FACP Room	Passed
Confirmed receipt of all signals with operator 33 and took system off test.				
01001810	3	Battery	1st FACP Room–Control Panel	Passed
Battery passed load test at 4.87 amps.				
01001811	4	Battery	1st FACP Room–Control Panel	Passed
Battery passed load test at 4.63 amps.				
01001840	5	Battery	4th Electrical Room	Passed
Battery passed load test at 4.57 amps.				
01001841	6	Battery	4th Electrical Room	Passed
Battery passed load test at 4.64 amps.				
<b>Initiating</b>				
01001800	7	Smoke Detector	3rd Elevator Lobby	Failed to Report
This device failed to report an alarm or trouble to the panel.				
01001817	8	Pull Station	3rd Stair A	Failed Operation
Handle on device is broken and will not initiate an alarm.				
<b>Monitor</b>				
01001778	9	Monitoring	1st FACP Room	Passed
Operator 3 put system on test for 8 hours. Operator 3 extended test period until 4pm.				

# Inspection & Testing

Generated by: BuildingReports.com

<b>Building: 2014 Sample Inspection Report</b>	<b>Control Panel: 1 - EST 3</b>
--	---------------------------------

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Auxiliary</b>				
Elevator	1st Elevator Lobby	Tested	6:36:15 AM	01/10/2014
Elevator	2nd Elevator Lobby	Tested	6:46:14 AM	01/10/2014
Fan Shutdown	All Floors HVAC	Tested	6:53:16 AM	01/10/2014
Fan Start	Penthouse Stairwell A	Tested	7:06:12 AM	01/10/2014
Fan Start	Penthouse Stairwell B	Tested	7:17:14 AM	01/10/2014
Locking Device	1st Main Entrance	Tested	7:45:46 AM	01/10/2014
Locking Device	4th Stair A	Tested	7:59:57 AM	01/10/2014
Locking Device	4th Stair B	Tested	7:57:23 AM	01/10/2014
Releasing Device	All Floors Elevator Lobby	Tested	7:29:15 AM	01/10/2014
Stairwell Exit	2nd Stair A	Tested	8:00:48 AM	01/10/2014
Stairwell Exit	3rd Stair B	Tested	8:16:15 AM	01/10/2014
Stairwell Exit	4th Stair A	Tested	7:59:07 AM	01/10/2014
Stairwell Exit	5th Stair B	Tested	8:11:17 AM	01/10/2014
Stairwell Exit	Penthouse Stair A	Tested	7:57:16 AM	01/10/2014
<b>Control</b>				
Annunciator	1st Lobby	Tested	1:43:21 PM	01/10/2014
Battery	1st FACP Room-Control Panel	Tested	9:49:55 AM	01/10/2014
Battery	1st FACP Room-Control Panel	Tested	9:54:52 AM	01/10/2014
Battery	4th Electrical Room	Tested	2:08:45 PM	01/10/2014
Battery	4th Electrical Room	Tested	2:10:16 PM	01/10/2014
Communicator	1st FACP Room	Tested	3:37:14 PM	01/10/2014
Control Panel	1st FACP Room	Tested	6:07:06 AM	01/10/2014
Handset	1st FACP Room	Tested	2:32:14 PM	01/10/2014
Handset	1st FACP Room	Tested	2:33:32 PM	01/10/2014
Handset	1st FACP Room	Tested	2:33:39 PM	01/10/2014
Handset	1st FACP Room	Tested	2:33:50 PM	01/10/2014
Handset	1st FACP Room	Tested	2:33:55 PM	01/10/2014
Phone Jack	1st Stair A	Tested	3:04:23 PM	01/10/2014
Phone Jack	1st Stair B	Tested	3:06:19 PM	01/10/2014
Phone Jack	2nd Stair A	Tested	3:02:19 PM	01/10/2014
Phone Jack	2nd Stair B	Tested	3:00:17 PM	01/10/2014
Phone Jack	3rd Stair A	Tested	2:57:27 PM	01/10/2014
Phone Jack	3rd Stair B	Tested	2:58:28 PM	01/10/2014
Phone Jack	4th Stair A	Tested	2:57:16 PM	01/10/2014
Phone Jack	4th Stair B	Tested	2:54:41 PM	01/10/2014
Phone Jack	5th Stair A	Tested	2:46:44 PM	01/10/2014
Phone Jack	5th Stair B	Tested	2:54:19 PM	01/10/2014
Phone Jack	Penthouse Elevator Machine Room	Tested	2:44:11 PM	01/10/2014

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Power Supply	1st FACP Room	Tested	9:33:51 AM	01/10/2014
Power Supply	4th Electrical Room	Tested	2:05:37 PM	01/10/2014
Power Supply	Penthouse Elevator Machine Room	Tested	8:18:39 AM	01/10/2014
<b>Initiating</b>				
Duct Detector	1st Mechanical Room	Tested/Cleaned	12:40:00 PM	01/10/2014
Duct Detector	2nd Mechanical Room	Tested/Cleaned	12:40:06 PM	01/10/2014
Duct Detector	3rd Mechanical Room	Tested/Cleaned	12:40:10 PM	01/10/2014
Duct Detector	4th Mechanical Room	Tested/Cleaned	12:40:19 PM	01/10/2014
Duct Detector	5th Mechanical Room	Tested/Cleaned	12:40:14 PM	01/10/2014
Heat Detector	1st Electrical Room	Tested	2:28:16 PM	01/10/2014
Heat Detector	2nd Electrical Room	Tested	2:24:13 PM	01/10/2014
Heat Detector	3rd Electrical Room	Tested	2:18:13 PM	01/10/2014
Heat Detector	4th Electrical Room	Tested	2:14:37 PM	01/10/2014
Heat Detector	5th Electrical Room	Tested	2:12:41 PM	01/10/2014
Pull Station	1st Loading Dock Exit	Tested	10:42:16 AM	01/10/2014
Pull Station	1st Main Entrance	Tested	10:40:08 AM	01/10/2014
Pull Station	2nd Stair A	Tested	10:39:19 AM	01/10/2014
Pull Station	2nd Stair B	Tested	10:37:27 AM	01/10/2014
Pull Station	3rd Stair B	Tested	10:33:39 AM	01/10/2014
Pull Station	4th Stair A	Tested	10:05:56 AM	01/10/2014
Pull Station	4th Stair B	Tested	10:05:15 AM	01/10/2014
Pull Station	5th Stair A	Tested	10:03:13 AM	01/10/2014
Pull Station	5th Stair B	Tested	10:04:13 AM	01/10/2014
Pull Station	Penthouse Elevator Machine Room	Tested	9:59:44 AM	01/10/2014
Smoke Detector	1st Elevator Lobby	Tested/Cleaned	10:34:43 AM	01/10/2014
Smoke Detector	1st FACP Room	Tested/Cleaned	10:34:53 AM	01/10/2014
Smoke Detector	1st Telephone Closet	Tested/Cleaned	10:34:47 AM	01/10/2014
Smoke Detector	2nd Elevator Lobby	Tested/Cleaned	10:34:39 AM	01/10/2014
Smoke Detector	2nd Telephone Closet	Tested/Cleaned	10:34:34 AM	01/10/2014
Smoke Detector	3rd Telephone Closet	Tested/Cleaned	10:34:30 AM	01/10/2014
Smoke Detector	4th Elevator Lobby	Tested/Cleaned	10:34:17 AM	01/10/2014
Smoke Detector	4th Telephone Closet	Tested/Cleaned	10:34:13 AM	01/10/2014
Smoke Detector	5th Elevator Lobby	Tested/Cleaned	10:34:00 AM	01/10/2014
Smoke Detector	5th Telephone Closet	Tested/Cleaned	10:34:08 AM	01/10/2014
Smoke Detector	Penthouse Elevator Machine Room	Tested/Cleaned	10:33:53 AM	01/10/2014
Waterflow Switch	1st Stair B	Tested	1:16:13 PM	01/10/2014
Waterflow Switch	2nd Stair B	Tested	1:09:13 PM	01/10/2014
Waterflow Switch	3rd Stair B	Tested	1:05:13 PM	01/10/2014
Waterflow Switch	4th Stair B	Tested	12:54:59 PM	01/10/2014
Waterflow Switch	5th Stair B	Tested	12:51:14 PM	01/10/2014
<b>Monitor</b>				
Monitoring	1st FACP Room	Tested	6:07:24 AM	01/10/2014
<b>Supervisory</b>				
Tamper Switch	1st Stair B	Tested	12:46:18 PM	01/10/2014
Tamper Switch	2nd Stair B	Tested	12:44:13 PM	01/10/2014
Tamper Switch	3rd Stair B	Tested	12:42:11 PM	01/10/2014
Tamper Switch	4th Stair B	Tested	12:40:27 PM	01/10/2014
Tamper Switch	5th Stair B	Tested	12:38:18 PM	01/10/2014

Device Type	Location	Service	Time	Date
<i>Failed/Other</i>				
<b>Alarm</b>				
Pre-Action System	3rd Computer Room	Bypassed	3:24:03 PM	01/10/2014
<b>Control</b>				
Battery	1st FACP Room-Power Supply	Inspected	9:43:40 AM	01/10/2014
Battery	1st FACP Room-Power Supply	Tested	9:44:34 AM	01/10/2014
<b>Initiating</b>				
Pull Station	3rd Stair A	Tested	10:26:41 AM	01/10/2014
Smoke Detector	3rd Computer Room	Bypassed	3:23:04 PM	01/10/2014
Smoke Detector	3rd Computer Room	Bypassed	3:23:32 PM	01/10/2014
Smoke Detector	3rd Elevator Lobby	Tested/Cleaned	10:34:24 AM	01/10/2014
Device Type	Location	Service	Time	Date
<i>Untested</i>				
<b>Initiating</b>				
Smoke Detector	3rd North Atrium			
Smoke Detector	3rd South Atrium			
<b>Monitor</b>				
Damper	3rd North Atrium			
Damper	3rd North Atrium			
Damper	3rd South Atrium			
Damper	3rd South Atrium			

# Service Summary

Generated by: BuildingReports.com

Building: 2014 Sample Inspection Report		
<i>The Service Summary section provides an overview of the services performed in this report.</i>		
Device Type	Service	Quantity
<b><i>Failed/Other</i></b>		
Battery	Inspected	1
Battery	Tested	1
Pre-Action System	Bypassed	1
Pull Station	Tested	1
Smoke Detector	Bypassed	2
Smoke Detector	Tested/Cleaned	1
Total		7
<b><i>Passed</i></b>		
Annunciator	Tested	1
Battery	Tested	4
Communicator	Tested	1
Control Panel	Tested	1
Duct Detector	Tested/Cleaned	5
Elevator	Tested	2
Fan Shutdown	Tested	1
Fan Start	Tested	2
Handset	Tested	5
Heat Detector	Tested	5
Locking Device	Tested	3
Monitoring	Tested	1
Phone Jack	Tested	11
Power Supply	Tested	3
Pull Station	Tested	10
Releasing Device	Tested	1
Smoke Detector	Tested/Cleaned	11
Stairwell Exit	Tested	5
Tamper Switch	Tested	5
Waterflow Switch	Tested	5
Total		82
<b><i>Untested</i></b>		
Damper		4
Smoke Detector		2
Total		6

# Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: 2014 Sample Inspection Report		Control Panel: 1 - EST 3		
<p><i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i></p>				
Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Elevator</b>				
Recall Primary	1st Elevator Lobby	Passed	01001779	☛
Recall Alternate	2nd Elevator Lobby	Passed	01001780	☛
<b>Fan Shutdown</b>				
Supply	All Floors HVAC	Passed	01001781	☛
<b>Fan Start</b>				
Pressurization	Penthouse Stairwell A	Passed	01001782	☛
Pressurization	Penthouse Stairwell B	Passed	01001783	☛
<b>Locking Device</b>				
Magnetic Lock	1st Main Entrance	Passed	01001790	☛
Electric Strike	4th Stair A	Passed	01001792	☛
Electric Strike	4th Stair B	Passed	01001791	☛
<b>Releasing Device</b>				
Door Holders	All Floors Elevator Lobby	Passed	01001784	☛
<b>Stairwell Exit</b>				
	2nd Stair A	Passed	01001787	☛
	3rd Stair B	Passed	01001789	☛
	4th Stair A	Passed	01001786	☛
	5th Stair B	Passed	01001788	☛
	Penthouse Stair A	Passed	01001785	☛
<b>Smoke Detector</b>				
Elevator Recall	1st Elevator Lobby	Passed	01001804	☛
Elevator Recall	2nd Elevator Lobby	Passed	01001803	☛
Elevator Recall	4th Elevator Lobby	Passed	01001799	☛
Elevator Recall	5th Elevator Lobby	Passed	01001796	☛
Elevator Recall	Penthouse Elevator Machine Room	Passed	01001795	☛
<b><i>Failed/Other</i></b>				
<b>Smoke Detector</b>				
Pre-Action System	3rd Computer Room	Access Denied	02366554	☛
Pre-Action System	3rd Computer Room	Access Denied	02366555	☛
Elevator Recall	3rd Elevator Lobby	Failed to Report	01001800	☛

# Sound and Visual Testing

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: 2014 Sample Inspection Report						
<p><i>The Sound and Visual Testing section lists various points throughout your building where audible and visual alarm notification devices were tested. Any bar-coded audible and visual devices will appear in the Inspection and Testing section of this report. Items in this section are grouped by Passed or Failed/Other. Where specific decibel readings were recorded, they will appear under the ambient and alarm columns. The Voice column indicates whether the Sound Test Point passed the Voice Intelligibility requirements. The STI or Sound Transmission Index is shown if recorded.</i></p>						
Location	Comment	Ambient dB	Alarm dB	Intelligibility		Sound Test
				Voice	STI	
<b><i>Passed</i></b>						
<b>Sound Test Points</b>						
Penthouse Elevator Machine Room	Passed	62	91	*		0001
5th Stair A	Passed	55	83	*		0002
5th Elevator Lobby	Passed	55	84	*		0003
4th Cubicle Area	Passed	55	79	*		0004
4th Outside Bathrooms	Passed	55	81	*		0005
3rd Stair B	Passed	55	82	*		0006
3rd Computer Room	Passed	63	89	*		0007
2nd Elevator Lobby	Passed	55	83	*		0008
2nd Cubicle Area	Passed	55	83	*		0009
1st Outside Bathrooms	Passed	55	84	*		0010
1st Lobby	Passed	55	92	*		0011

# Sensitivity Testing

Generated by: BuildingReports.com

Building: 2014 Sample Inspection Report				Control Panel: 1 - EST 3		
<p><i>The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.</i></p>						
Location	Address	Model #	Range	Value	ScanID	
<b><i>Passed</i></b>						
<b>Smoke Detector</b>						
1st Elevator Lobby	1-01012321	SIGA-PS	0.67 - 3.77	1.83	01001804	
1st FACP Room	1-01012320	SIGA-PS	0.67 - 3.77	2.19	01001806	
1st Telephone Closet	1-01012024	SIGA-PS	0.67 - 3.77	2.31	01001805	
2nd Elevator Lobby	1-01012322	SIGA-PS	0.67 - 3.77	1.72	01001803	
2nd Telephone Closet	1-01012323	SIGA-PS	0.67 - 3.77	1.66	01001802	
3rd Telephone Closet	1-01012324	SIGA-PS	0.67 - 3.77	1.66	01001801	
4th Elevator Lobby	1-01012326	SIGA-PS	0.67 - 3.77	1.47	01001799	
4th Telephone Closet	1-01012327	SIGA-PS	0.67 - 3.77	1.43	01001798	
5th Elevator Lobby	1-01012329	SIGA-PS	0.67 - 3.77	1.62	01001796	
5th Telephone Closet	1-01012328	SIGA-PS	0.67 - 3.77	1.57	01001797	
Penthouse Elevator Machine Room	1-01012330	SIGA-PS	0.67 - 3.77	1.50	01001795	
<b><i>Failed/Other</i></b>						
<b>Smoke Detector</b>						
3rd Elevator Lobby	1-01012325	SIGA-PS	0.67 - 3.77	1.37	01001800	

# Air Flow Testing

Generated by: BuildingReports.com

Building: 2014 Sample Inspection Report			Control Panel: 1 - EST 3		
<i>The Air Flow Testing report details the test measurements of Air Duct type smoke detectors. Items are grouped by Passed or Failed/Other. Pressure and velocity test readings are recorded and compared with acceptable results. Normally, Device readings that fall outside the range of acceptance are listed in Failed/Other.</i>					
Location	Address	Comment	Ins/H2 O	Ft/Min	ScanID
<b><i>Passed</i></b>					
<b>Duct Detector</b>					
1st Mechanical Room	1-01012005	Passed	.011	4133	01001827
2nd Mechanical Room	1-01012004	Passed	.013	4411	01001826
3rd Mechanical Room	1-01012003	Passed	.016	4523	01001825
4th Mechanical Room	1-01012002	Passed	.010	4216	01001824
5th Mechanical Room	1-01012001	Passed	.012	4138	01001823

# Smoke Management Testing

Generated by: BuildingReports.com

Building: 2014 Sample Inspection Report		Control Panel: 1 - EST 3		
<p><i>The Smoke Management Testing section details the test and inspection of device items that are involved in controlling the spread of smoke in a building. Items are grouped by Passed or Failed/Other.</i></p>				
Location	Description	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Fan Shutdown</b>				
All Floors HVAC	Supply	Passed	01001781	*
<b>Fan Start</b>				
Penthouse Stairwell A	Pressurization	Passed	01001782	*
Penthouse Stairwell B	Pressurization	Passed	01001783	*
<b>Releasing Device</b>				
All Floors Elevator Lobby	Door Holders	Passed	01001784	*

# *Stairwell Pressurization Testing*

*Generated by: BuildingReports.com*

Building: 2014 Sample Inspection Report		Control Panel: 1 - EST 3				
<i>The Stairwell Pressurization Testing section details the measurements recorded at the stairwell exit door, and pressure readings recorded within the stairwell with one door open, and two doors open. Items are grouped by Passed or Failed/Other.</i>						
Location	Comment	Ft/Lb s	Stair	1 dr	2 drs	ScanID
<b><i>Passed</i></b>						
<b>Stairwell Exit</b>						
2nd Stair A	Passed	25	.021	.015	.010	01001787
3rd Stair B	Passed	26	.020	.014	.010	01001789
4th Stair A	Passed	24	.023	.012	.010	01001786
5th Stair B	Passed	27	.023	.017	.014	01001788
Penthouse Stair A	Passed	26	.031	.014	.011	01001785

# Time, Temperature & Level Testing

Generated by: BuildingReports.com

Building: 2014 Sample Inspection Report			Control Panel: 1 - EST 3			
<p><i>The Time, Temperature, &amp; Level Testing section details the measurements taken from various devices that are designed to respond in a certain amount of time, respond at a certain temperature, or respond within the acceptable range of volume or level. Items are grouped by Passed or Failed/Other.</i></p>						
Type	Location	Comment	Se c	De g	Lvl	ScanID
<b><i>Passed</i></b>						
<b>Heat Detector</b>						
Fixed Temperature	1st Electrical Room	Passed	13	n/a	n/a	01001847
Fixed Temperature	2nd Electrical Room	Passed	13	n/a	n/a	01001846
Fixed Temperature	3rd Electrical Room	Passed	10	n/a	n/a	01001845
Fixed Temperature	4th Electrical Room	Passed	12	n/a	n/a	01001843
Fixed Temperature	5th Electrical Room	Passed	10	n/a	n/a	01001842
<b>Waterflow Switch</b>						
	1st Stair B	Passed	31	n/a	n/a	01001837
	2nd Stair B	Passed	27	n/a	n/a	01001836
	3rd Stair B	Passed	22	n/a	n/a	01001835
	4th Stair B	Passed	25	n/a	n/a	01001834
	5th Stair B	Passed	32	n/a	n/a	01001833

# Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: 2014 Sample Inspection Report			Control Panel: 1 - EST 3			
<p><i>The Control &amp; Power Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</i></p>						
Type	Location	Comment	Amps	Volts	Pre Test	Post Test
<b><i>Passed</i></b>						
<b>Battery</b>						
Sealed Lead Acid	1st FACP Room–Control Panel	Passed	7.5	12	13.7	13.5
Sealed Lead Acid	1st FACP Room–Control Panel	Passed	7.5	12	13.6	13.3
Sealed Lead Acid	4th Electrical Room	Passed	7.5	12	13.3	13.1
Sealed Lead Acid	4th Electrical Room	Passed	7.5	12	13.5	13.3
<b>Power Supply</b>						
	1st FACP Room	Passed	8	24		
	4th Electrical Room	Passed	8	24		
	Penthouse Elevator Machine Room	Passed	8	24		
<b><i>Failed/Other</i></b>						
<b>Battery</b>						
Sealed Lead Acid	1st FACP Room–Power Supply	Date Expired	7.5	12		
Sealed Lead Acid	1st FACP Room–Power Supply	Failed Test	7.5	12		

# Inventory & Warranty Report

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: 2014 Sample Inspection Report		Control Panel: 1 - EST 3		
<p><i>The Inventory &amp; Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i></p>				
Device or Item	Category	% of Inventory	Quantity	
Damper	Monitor	3.77%	4	
Smoke Detector	Initiating	15.09%	16	
Control Panel	Control	0.94%	1	
Monitoring	Monitor	0.94%	1	
Elevator	Auxiliary	1.89%	2	
Fan Shutdown	Auxiliary	0.94%	1	
Fan Start	Auxiliary	1.89%	2	
Releasing Device	Auxiliary	0.94%	1	
Locking Device	Auxiliary	2.83%	3	
Stairwell Exit	Auxiliary	4.72%	5	
Power Supply	Control	2.83%	3	
Battery	Control	5.66%	6	
Pull Station	Initiating	10.38%	11	
Tamper Switch	Supervisory	4.72%	5	
Duct Detector	Initiating	4.72%	5	
Waterflow Switch	Initiating	4.72%	5	
Annunciator	Control	0.94%	1	
Heat Detector	Initiating	4.72%	5	
Handset	Control	4.72%	5	
Phone Jack	Control	10.38%	11	
Pre-Action System	Alarm	0.94%	1	
Communicator	Control	0.94%	1	
Type	Qty	Model #	Description	Install Date
<b><i>In Service - 3 Years to 5 Years</i></b>				
<b>EST</b>				
Pull Station	1	SIGA-278	Dual Action	01/01/2010
<b><i>In Service - 5 Years to 10 Years</i></b>				
<b>EST</b>				
Heat Detector	1	SIGA-HRS	Fixed Temperature	01/01/2009
<b>Werker</b>				
Battery	2	WKA 12-7.5F	Sealed Lead Acid	01/01/2009
<b>Damper</b>				
Damper	4		Open	05/16/2005
<b>EST</b>				
Smoke Detector	2	SIGA-PS	Photoelectric	05/16/2005
<b>Power-Sonic</b>				
Battery	2	PS-127	Sealed Lead Acid	02/01/2005

Elevator	1		Recall Alternate	05/01/2004
Elevator	1		Recall Primary	05/01/2004
Fan Shutdown	1		Supply	05/01/2004
Fan Start	2		Pressurization	05/01/2004
Locking Device	2		Electric Strike	05/01/2004
Locking Device	1		Magnetic Lock	05/01/2004
Monitoring	1		All Signals	05/01/2004
Releasing Device	1		Door Holders	05/01/2004
Stairwell Exit	5			05/01/2004
<b>B&amp;B Battery</b>				
Battery	2	BB-1275	Sealed Lead Acid	05/01/2004
<b>EST</b>				
Annunciator	1	3-LCD	LCD Display	05/01/2004
Communicator	1	3-MODCOM	Digital Communicator	05/01/2004
Control Panel	1	3		05/01/2004
Duct Detector	5	SIGA-DH	Photoelectric	05/01/2004
Heat Detector	4	SIGA-HRS	Fixed Temperature	05/01/2004
Pull Station	10	SIGA-278	Dual Action	05/01/2004
Smoke Detector	14	SIGA-PS	Photoelectric	05/01/2004
<b>Fike</b>				
Pre-Action System	1	SHP -1	Double-Interlock	05/01/2004
<b>Fire-Lite</b>				
Power Supply	1	FCPS-24FS6		05/01/2004
<b>Notifier</b>				
Power Supply	1	FCPS-24S8		05/01/2004
<b>Potter Electric</b>				
Tamper Switch	5	OSYSU-1		05/01/2004
Waterflow Switch	5	VSR-F-10		05/01/2004
<b><i>In Service - 10 Years to 15 Years</i></b>				
<b>EST</b>				
Handset	5	6380-1		03/01/1999
Phone Jack	11	PJ-1		03/01/1999
<b><i>In Service - 25 Years or Older</i></b>				
<b>FCI</b>				
Power Supply	1	SNAC		08/01/1984

# Zone Address Report

Generated by: [BuildingReports.com](http://BuildingReports.com)

Building: 2014 Sample Inspection Report	Control Panel: 1 - EST 3
---	--------------------------

*The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.*

Address	Device Type	Location	Description	ScanID
<b>Zone/Circuit: 01</b>				
01034	Smoke Detector	3rd North Atrium	Photoelectric	02366443
01038	Smoke Detector	3rd South Atrium	Photoelectric	02366447
<b>Zone/Circuit: 01011020</b>				
	Pull Station	Penthouse Elevator Machine Room	Dual Action	01001812
<b>Zone/Circuit: 01011021</b>				
	Pull Station	5th Stair A	Dual Action	01001813
<b>Zone/Circuit: 01011022</b>				
	Pull Station	5th Stair B	Dual Action	01001814
<b>Zone/Circuit: 01011023</b>				
	Pull Station	4th Stair B	Dual Action	01001815
<b>Zone/Circuit: 01011024</b>				
	Pull Station	4th Stair A	Dual Action	01001816
<b>Zone/Circuit: 01011025</b>				
	Pull Station	3rd Stair A	Dual Action	01001817
<b>Zone/Circuit: 01011026</b>				
	Pull Station	3rd Stair B	Dual Action	01001818
<b>Zone/Circuit: 01011027</b>				
	Pull Station	2nd Stair B	Dual Action	01001819
<b>Zone/Circuit: 01011028</b>				
	Pull Station	2nd Stair A	Dual Action	01001820
<b>Zone/Circuit: 01011029</b>				
	Pull Station	1st Main Entrance	Dual Action	01001821
<b>Zone/Circuit: 01011030</b>				
	Pull Station	1st Loading Dock Exit	Dual Action	01001822
<b>Zone/Circuit: 01012001</b>				
	Duct Detector	5th Mechanical Room	Photoelectric	01001823
<b>Zone/Circuit: 01012002</b>				
	Duct Detector	4th Mechanical Room	Photoelectric	01001824
<b>Zone/Circuit: 01012003</b>				
	Duct Detector	3rd Mechanical Room	Photoelectric	01001825
<b>Zone/Circuit: 01012004</b>				

Duct Detector	2nd Mechanical Room	Photoelectric	01001826
<b>Zone/Circuit: 01012005</b>			
Duct Detector	1st Mechanical Room	Photoelectric	01001827
<b>Zone/Circuit: 01012006</b>			
Tamper Switch	5th Stair B		01001828
<b>Zone/Circuit: 01012007</b>			
Tamper Switch	4th Stair B		01001829
<b>Zone/Circuit: 01012009</b>			
Tamper Switch	3rd Stair B		01001830
<b>Zone/Circuit: 01012010</b>			
Tamper Switch	2nd Stair B		01001831
<b>Zone/Circuit: 01012011</b>			
Tamper Switch	1st Stair B		01001832
<b>Zone/Circuit: 01012012</b>			
Waterflow Switch	5th Stair B		01001833
<b>Zone/Circuit: 01012013</b>			
Waterflow Switch	4th Stair B		01001834
<b>Zone/Circuit: 01012015</b>			
Waterflow Switch	3rd Stair B		01001835
<b>Zone/Circuit: 01012016</b>			
Waterflow Switch	2nd Stair B		01001836
<b>Zone/Circuit: 01012017</b>			
Waterflow Switch	1st Stair B		01001837
<b>Zone/Circuit: 01012018</b>			
Heat Detector	5th Electrical Room	Fixed Temperature	01001842
<b>Zone/Circuit: 01012020</b>			
Heat Detector	4th Electrical Room	Fixed Temperature	01001843
<b>Zone/Circuit: 01012021</b>			
Heat Detector	3rd Electrical Room	Fixed Temperature	01001845
<b>Zone/Circuit: 01012022</b>			
Heat Detector	2nd Electrical Room	Fixed Temperature	01001846
<b>Zone/Circuit: 01012023</b>			
Heat Detector	1st Electrical Room	Fixed Temperature	01001847
<b>Zone/Circuit: 01012024</b>			
Smoke Detector	1st Telephone Closet	Photoelectric	01001805
<b>Zone/Circuit: 01012320</b>			
Smoke Detector	1st FACP Room	Photoelectric	01001806
<b>Zone/Circuit: 01012321</b>			
Smoke Detector	1st Elevator Lobby	Photoelectric	01001804
<b>Zone/Circuit: 01012322</b>			
Smoke Detector	2nd Elevator Lobby	Photoelectric	01001803

<b>Zone/Circuit: 01012323</b>			
Smoke Detector	2nd Telephone Closet	Photoelectric	01001802
<b>Zone/Circuit: 01012324</b>			
Smoke Detector	3rd Telephone Closet	Photoelectric	01001801
<b>Zone/Circuit: 01012325</b>			
Smoke Detector	3rd Elevator Lobby	Photoelectric	01001800
<b>Zone/Circuit: 01012326</b>			
Smoke Detector	4th Elevator Lobby	Photoelectric	01001799
<b>Zone/Circuit: 01012327</b>			
Smoke Detector	4th Telephone Closet	Photoelectric	01001798
<b>Zone/Circuit: 01012328</b>			
Smoke Detector	5th Telephone Closet	Photoelectric	01001797
<b>Zone/Circuit: 01012329</b>			
Smoke Detector	5th Elevator Lobby	Photoelectric	01001796
<b>Zone/Circuit: 01012330</b>			
Smoke Detector	Penthouse Elevator Machine Room	Photoelectric	01001795
<b>Zone/Circuit: 01013011</b>			
Pre-Action System	3rd Computer Room	Double-Interlock	02366557